

MV Cable Route Cross-Over With Drainage

80

110

165

800

900

510

SUB DRAINAGE CONCRETE

Warning Tape

FPE #110

FPE #110

FPE #110

FPE #110

3021x110 mm2 Switchgear
30W MISCORRY
110 mm2 Duct Bank

3021x110 mm2 Switchgear
30W MISCORRY
110 mm2 Duct Bank

3021x110 mm2 Switchgear
30W MISCORRY
110 mm2 Duct Bank

3021x110 mm2 Switchgear
30W MISCORRY
110 mm2 Duct Bank

Fiber Only Cells
110 mm OD Duct Bank

NOTES
Any modification to the drainage depth requires a proportional adjustment to the cable trench depth.

Client:  	Consultant:	
	Contractor:	Sub Contractor: