







4 5 6 7 8 9 10

Page	Description	Revision				
		0	A	B	C	D
1	COVER	X	X	X	X	
2	LIST OF CONTACT	X	X	X	X	
3	LIST OF SYMBOLES	X	X	X	X	
4	GENERAL SINGLE LINE DIAGRAM 230KV	X	X	X	X	
5	DESCERPTION OF DEVICE 230 KV	X	X	X	X	
6	DESCERPTION OF DEVICE 230 KV CT&CVT	X	X	X	X	

[illegible]

SYMBOL	DESIGNATION	SYMBOL	DESIGNATION	SYMBOL	DESIGNATION
	CIRCUIT BREAKER		3 PHASE CAPACITIVE VOLTAGE TRANSFORMER WITH LINE MATCHING UNIT		MOTOR OPERATED DISCONNECTING SWITCH WITH MOTOR OPERATED EARCHING SWITCH
	CURRENT TRANSFORMER		3 PHASE CAPACITIVE VOLTAGE TRANSFORMER		ON LOAD DISCONNECTING SWITCH
	SURGE ARRESTER WITH SURGE COUNTER		SINGLE PHASE CAPACITIVE VOLTAGE TRANSFORMER		
	MOTOR OPERATED DISCONNECTING SWITCH		TEMPORARY EARTH POINT		LINE TRAP

7 NATIONAL BANKING CORPORATION 	SUB-CONTRACTOR'S LOGO				MD1 - RF - 00 - SS - E - 02 - NGO - 900 DWG./Doc. No.	REV. NO. : C SHEET: 3 OF 6	 NIROO TAVAN GOSTAR KOHAN SHARAH COMPANY	 230KV AIS S /S
	SUB CONTRACTOR DMC. NO.:							
	DMC./Doc. No.							
	DRAWING TITLE:							
	LIST OF SYMBOLS							
A	Doc. To Let. No. 12105-NAHE-SC-1-4639	DMC	DMC/DMC	104.11.87	DESIGN STAGE :	FILE No.	PROJECT :	KHAATOON ABAD GAS POWER PLANT
D	FIRST ISSUE	DMC	DMC/DMC	104.10.16				
REV.	DESCRIPTION	DMC	DMC	DATE				

	Description
-Q11	1-3P.DS,245KV , 3150A,50KA , 1Sec
-Q01	3-1P.CB,245KV , 3150A,50KA , 1Sec
-Q12	1-3P.DS,245KV , 3150A,50KA , 1Sec
-Q31	1-3P.DS,245KV , 3150A,50KA , 1Sec
-Q03	3-1P.CB,245KV , 3150A,50KA , 1Sec
-Q32	1-3P.DS,245KV , 3150A,50KA , 1Sec
-Q21	1-3P.DS,245KV , 3150A,50KA , 1Sec
-Q02	1-3P.CB,245KV , 3150A,50KA , 1Sec
-Q22	1-3P.DS,245KV , 3150A,50KA , 1Sec
-Q91	1-3P.DS,245KV , 3150A,50KA , 1Sec
-Q81	1-3P.ES,245KV , 3150A,50KA , 1Sec
-Q92	1-3P.DS,245KV , 3150A,50KA , 1Sec
-Q82	1-3P.ES,245KV , 3150A,50KA , 1Sec
-F1,-F1.1,-F1.2	3-LA's,WITH S.C,198KV,20KA,CLASS 4
-L1,-L2	L.T'S,230KV,2000A,1mH,50KA,1Sec,PHASE B,C

[illegible]

